



### N510 BACnet DIGITAL THERMOSTAT 7-DAY PROGRAMMABLE SCHEDULE VARIABLE AIR VOLUME, MODULATING COOLING • 2-PIPE SYSTEM

#### Discharge Air Temperature

The Discharge Air Temperature sensor (DAT) provides the controller with the coil leaving air temperature (LAT). This is used to control the modulating valve to achieve a pre-set, but adjustable, discharge temperature. On cooling, this controls humidity.

#### SEQUENCE OF OPERATION:

##### Modulating Cooling

On a call for cooling, the chilled water valve will begin to modulate open. The valve will continue to open until the discharge air temperature reaches 52°F (11°C). Simultaneously, the fan will modulate from minimum airflow to maximum airflow to achieve room set point. Upon a decrease in cooling demand, the sequence will reverse.

##### Deadband

With no demand in the space, there will be no call for cooling. The fan will be at a deadband set minimum airflow. The chilled water valve will be off.

#### Notes:

1. EZstat is factory programmed for the specific sequence of operation.
2. EZstat is also factory calibrated when airflow settings are provided for easy start-up.
3. Field commissioning (password protected):
  - a. Max. and Min. airflow settings are field adjustable between the ranges on the unit's ECM fan curve calibration chart.
  - b. Deadband differential and other parameters are also adjustable.
  - c. Refer to EZstat Application Guide/IOM.
4. Remote mounted 24 VAC thermostat is field wired (by others). Refer to application specific wiring diagram.
5. Thermostats baseplate mounts to a standard 2" (51) x 4" (102) vertical handy box.



SCHEDULE TYPE:

PROJECT:

ENGINEER:

CONTRACTOR:

Dimension are in inches (mm).

DATE	B SERIES	SUPERSEDES	DRAWING NO.
9 - 23 - 14	FCS	NEW	FCS-N510